

# CT Test Report



**Site ID:** 10737 LEXINGTON DRIVE  
**Customer:** TEC  
**Test Date:** Friday, March 3, 2017 1:51:04 PM (UTC+05:00)  
**Service:** 3-Phase, 4-Wire, Wye (3V, 3C) TR

**Account No:**  
**Tech 1:** MARTIN HIATT  
**Tech 2:**  
**Sys ID:** 3302-430329

**Comments:**

## Transformer Information

Phase	Manufacturer	Catalog No	Serial No	NPR:5	Bur. Class	Acc. Class
A	GEC Durham Industries	100K	3202191	200	0.5	0.3
B	GEC Durham Industries	100K	3202192	200	0.5	0.3
C	GEC Durham Industries	100K	3202193	200	0.5	0.3

## Ratio at Zero Burden

	A	B	C
<b>Measured</b>	200.969	200.130	201.050
<b>Error (%)</b>	0.484	0.065	0.525
<b>Phase Error (Deg)</b>	0.014	0.343	0.382
<b>Phase Error (Min)</b>	0' 51"	20' 35"	22' 55"
<b>Pri. Amps</b>	99.190	98.880	99.089
<b>Sec. Amps</b>	2.468	2.470	2.464

## Accuracy Parallelogram

